

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 346

Dated: 23/06/2025

It is certified that an inspection team headed by Mr. D.P. Singh Lab Incharge / sub Engg.

(Name of Officers with designation) from Mrs. Anita Jayant chemist

(Name of Department/ Office) inspected the Public Health Engineering Department Gwalior

(Name & Address of the school) on 21/06/2025 (date of inspection) and found that the
 Excellent Circle of studies (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of One year [23/06/2025 to 22/06/2026]

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Distrect Water Testing Laboratory
 P.H.E Division, Gwalior (M.P.)

D.P. Singh

Sub Engineer / Lab Incharge

PHED Gwalior

To

Manager

Excellent Circle of studies

Vicky Factory Tiraha, Shivpuri Link Road Gwalior,
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Public Health Engineering Department District Water- Testing Laboratory Gwalior


Test Report


Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:-Manager Excellent Circle Of Studies Vicky Factory Tiraha, Shiypuri Link Road , Gwalior M.P.			
Sample No.	Place of Collection and Details of Sample	Date of collection	
1	Drinking Water	20.06.2025	
2	-	-	
3	-	-	
4	-	-	
Particular of Sample :-			
Date of Receipt:- 20.06.2025		Time of Receipt: 11:05 AM	
Lab Reference No:		Date of Analysis: 21.06.2025	

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source				
PHYSICAL TESTE					Sample 1	Sample 2	Sample 3	Sample 4
1	Turbidity	NTU	1.0	5.0	1.8	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TESTE								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.1	-	-	-
6	Alkalinity	Mg/L	200	600	102	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	75	-	-	-
8	Nitrate as No3	Mg/L	45	45	04	-	-	-
9	Total hardness	Mg/L	200	600	182	-	-	-
10	Calcium as Ca	Mg/L	75	200	44	-	-	-
11	Magnesium as mg	Mg/L	30	100	16	-	-	-
12	Iron	Mg/L	0.3	1.0	0.17	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	304	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.12	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	06	-	-	-
BECT. FEACAL TESTE								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


CHEMIST
 Signature of Analyst
 District Water Testing Lab
 P.H.E. Division Gwalior


Lab Incharge
 District Water Testing Laboratory (M.P.)
 P.H.E. Division, Gwalior (M.P.)

No. 246 /PHED/ Date :- 23/6/25